

Log No. 90369

Permit No. _____

Basin 087

mwpr-2
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46061

1. OWNER Washoe County Dept of Water Resources ADDRESS AT WELL LOCATION 55 South 15th Ave
 MAILING ADDRESS 4930 Energy way Sparks, NV
Reno, NV 89502

2. LOCATION SE 1/4 NW 1/4 Sec 8 T 19 N 20 E Washoe County

PERMIT NO. 32-27-513 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Radio-Servic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel, Silty, Sand, Brown	Dry	0	11	11
Gravel, Sand, Silty Gray	moist	11	24	13
Gravel, Clay, silt	Wet	24	36	12
Gravel, Sand, Clay, Brown	Wet	36	58	22
Gravel, Silty, yellow-Brown	Wet	58	93	35

8. WELL CONSTRUCTION

Depth Drilled 93 Feet Depth Cased 93 Feet

HOLE DIAMETER (BIT SIZE)
 From To
6" Inches 0 Feet 93 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>sch 40</u>	<u>0</u>	<u>70</u>

Perforations:
 Type perforation Factory cut
 Size perforation .020
 From 70 feet to 90 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-65 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 68 feet to 93 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BOART longyear Contractor
 Address 32 Stokes Dr Po Box 1000 Contractor
Dayton, NV 89403
 Nevada contractor's license number issued by the State Contractor's Board 0010157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-214 8T2
 Signed Boart Longyear
 By driller performing actual drilling on site or contractor
 Date 8-15-03

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Date started 8-3 2003
 Date completed 8-4 2003

RECEIVED
 03 AUG 20 AM 10:57
 STATE ENGINEERS OFFICE