WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

mwPR-5

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90370
Permit No.
Basin 087

NOTICE OF INTENT NO. 46062

1. OWNER Washoe County Dept of Water Resources
MAILING ADDRESS 4930 Energy Way
Reno, NV 89502

ADDRESS AT WELL LOCATION 55 South 15th Ave
Sparks, NV

2. LOCATION SE ¼ NW ¼ Sec. B T 19 N/S R 20 E Washoe County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Roto-Sonic

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Gravel, Sand, Brown | Dry | 0 | 14 | 14 |
| Gravel, Silt, Sand | moist | 14 | 24 | 10 |
| Gravel, Silt, Clay | wet | 24 | 53 | 29 |

RECEIVED
03 AUG 20 AM 10:57
STATE ENGINEER'S OFFICE

Date started 8-7, 20 03
Date completed 8-7, 20 03

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 0 Feet Depth Cased 53 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 6 Inches | | 0 Feet | 53 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | Sch | 40 | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type perforation Factory cut
Size perforation .020
From 30 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 25
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 28 feet to 53 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BART Longyear (Contractor)
Address 32 Stokes Dr. Po Box 1000 (Contractor)
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller m-214 BT2
Signed (By driller performing actual drilling on site or contractor)
Date 8-16-03

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627