

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT



office use only  
Log No. 90374  
Permit No.  
Basin 087

NOTICE OF INTENT NO 48502  
5044 Westview Cir

1. OWNER Pat Assuras  
MAILING ADDRESS 5044 Westview Cir  
Sparks NV

ADDRESS AT WELL LOCATION  
2. Location NW 1/4 NW 1/4 Sec 1 T 19N R 20E Washoe County  
PERMIT NO. PARCEL NO. 030-203-10 SUBDIVISION NAME

| 3. WORK PERFORMED |           |             | 4. PROPOSED USE      |            |       | 5. WELL TYPE |        |     |
|-------------------|-----------|-------------|----------------------|------------|-------|--------------|--------|-----|
| New Well          | Replace   | Recondition | Domestic             | Irrigation | Test  | Cable        | Rotary | RVC |
| Deepen            | X Abandon | Other       | Municipal/Industrial | Monitor    | Stock | Air          | Other  | Mud |

6. LITHOLOGIC LOG

| Material                                                                                   | Water Strata | From | To | Thick-ness |
|--------------------------------------------------------------------------------------------|--------------|------|----|------------|
| Installed termie to 440' & pumped 5 yds of neat cement.                                    |              |      |    | 0          |
| We did get returns. The neat cement went down 10'. We capped the last 10' with sand grout. |              |      |    | 0          |
| We perf from 54 to 155 per Tim Hunt                                                        |              |      |    | 0          |

8. WELL CONSTRUCTION

Depth Drilled 440 feet Depth Cased 440 feet  
HOLE DIAMETER (BIT SIZE)

|          | From | To   |
|----------|------|------|
| inches 0 | feet | feet |
| inches   | feet | feet |
| inches   | feet | feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8              | 12.94               | 188                     | +1 1/2      | 440       |

Perforations:

| Type Perforation           | Factory & mills knife |
|----------------------------|-----------------------|
| Size perforation 3/32 x 3" |                       |
| From 54 feet to 155 feet   |                       |
| From 380 feet to 420 feet  |                       |
| From feet to feet          |                       |
| From feet to feet          |                       |
| From feet to feet          |                       |

Surface Seal X YES No Seal Type:  
Depth of Seal 50 feet X Neat Cement  
x Pumped Cement Grout  
Poured Concrete Grout

Gravel Packed: Yes No  
From feet to feet

RECEIVED  
03 JUL 28 AM 11:17  
STATE ENGINEERS OFFICE

9. WATER LEVEL

Static water level 376 feet below land surface  
Artesian flow 0 GPM 0 P.S.I.  
Water Temperature cold Degrees F Quality

Date started 7-8 -03  
Date completed 7-10 -03

7. WELL TEST DATA

| TEST METHOD: | Bailer                        | Pump | x Air Lift   |
|--------------|-------------------------------|------|--------------|
| G.P.M.       | Draw Down (Feet Below Static) |      | Time (hours) |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc.  
2290 Pioneer Drive  
Reno, NV 89509  
NV Contractors No. 14170  
NV Driller's Lic (on site) 2236

Signed Steve McKay  
By driller performing actual drilling on site or contractor  
Date 7-15 -03