WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90378
Permit No.
Basin 087

NOTICE OF INTENT NO. 46068

1. OWNER Regional Transportation Commission
MAILING ADDRESS 1105 Terminal Way Reno, NV 89502
ADDRESS AT WELL LOCATION between Vic-torian Ave + I-80 between 14th + 15th Streets, Sparks, NV

2. LOCATION SE ¼ SW ¼ Sec 5 T 19 N/S R 20 E WASHOE County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☒ Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND + GRAVEL		0	9	
COBBLES, GRAVEL		9	16	
SAND + GRAVEL		16	30	

RECEIVED
03 JUL 21 AM 11:23
STATE ENGINEERS OFFICE

Date started 7/15/03, 19
Date completed 7/15/03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6½ Inches		0 Feet	30 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	sch 40	PVC	0	15

Perforations:
Type perforation Factory slotted
Size perforation .020"
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 12½
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 30 feet to 12½ feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of ~~my~~ knowledge.
Name Bart Carpenter Contractor
Address Box 1000 Contractor
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's ~~license number issued by the~~ Division of Water Resources, the on-site driller M-2198
Signed [signature] By driller performing actual drilling on site or contractor
Date 7/16/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627