WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90390
Permit No.
Basin (0)
NOTICE OF INTENT NO. 49183

OWNER KRISTINE JOHNSON
MAILING ADDRESS 115 DEER TRAIL
FALLON, NV 89406

ADDRESS AT WELL LOCATION 115 DEER TRAIL

2. LOCATION NE 1/4 SW 1/4 Sec. 23 T 19 N/S R 29 E CHURCHILL County
PERMIT NO. Issued by Water Resources
8-322-06 Parcel No.
VENTURACCI Subdivision Name

3. WORK PERFORMED
[ ] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	13	12
BROWN CLAY		13	15	2
BROWN SAND		15	34	19
BROWN CLAY		34	38	4
GREY SAND		38	50	12
BLACK SILT/CLAY		50	70	20
GREY SAND		70	83	13
GREY CLAY		83	90	7
BROWN SAND		90	100	10
		100		

RECEIVED
03 AUG -6 AM 10:48
STATE ENGINEER'S OFFICE

Date started 6/30/~~1903~~ 2003, 19__
Date completed 7/15/~~1903~~ 2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	90	Feet
	Inches		Feet		Feet
6 5/8	Inches	90	Feet	100	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	100

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 90 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 90
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed By driller performing actual drilling on-site or contractor
Date 8/6/2003

USE ADDITIONAL SHEETS IF NECESSARY