REPORT NO. A03.065

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 90396
PERMIT NO.
BASIN 089
NOTICE OF INTENT NO. 49156

1. OWNER Melinda "Moe" Tumbusch
MAILING ADDRESS 690 Oro Loma Rd. Carson City, Nv. 89701

ADDRESS OF WELL 690 Oro Loma Rd.
Carson City, Nv. 89701

2. WELL LOCATION SE 1/4 SE 1/4 SEC 23 T 17 R 19 E Washoe COUNTY

PERMIT NO. PARCEL NO 50-236-01 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Salt Pepper Granite		73	100	27
Green Granite & Clay		100	123	23

RECEIVED
03 AUG -6 AM 11:18
STATE ENGINEERS OFFICE

Notes: Refer to original log for sanitary seal.

Date Started 7/1/03 Date Completed 7/2/03

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
Air	20+		1hr

8. WELL CONSTRUCTION
Depth Drilled 123 Depth Cased 123

HOLE DIAMETER (BIT SIZE)
61/4 Inches 73 Feet 123 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
5	9.69	.188	43	123

PERFORATIONS
Type Perforation Factory Size Perforation 3/32 X 3
From 83 Feet to 123 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL [ ] Yes [ ] No
SEAL TYPE [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout [ ] Bentonite
Seal Depth
PLACEMENT METHOD [ ] Pumped [ ] Poured
GRAVEL PACKED [ ] Yes [ ] No
From Feet to Feet

9. WATER LEVEL
Static Water Level 20 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service Inc.
Address 675 Edison Way
Reno, Nv. 89502

NV CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO ON SITE 2189

Signed
By driller performing actual drilling on site or contractor
Dated 7/2/03