

OFFICE USE ONLY  
 Permit No. 90401  
 Permit No. \_\_\_\_\_  
 Basin 102  
 NOTICE OF INTENT NO. 47911

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER GARY MCKAY ADDRESS AT WELL LOCATION BYBEE LANE  
 MAILING ADDRESS PO BOX 37, WELLINGTON NV. 89444  
 2. LOCATION NE 1/4 SE 1/4 Sec. 22 T 14 N R 23 E LYON County  
 PERMIT NO. 14-341-08 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
BWN. ADOBE CLAY	NO	0	4	4
SAND W/BWN. CLAY	NO	4	26	
HARD PAN	NO	26	28	
COARSE SAND	YES	28	64	
BWN. CLAY	NO	64	65	
MEDIUM SAND	YES	65	78	
BWN. CLAY	NO	78	86	
COARSE SAND	YES	86	102	
FINE SAND / STRIPS BWN CLAY	YES	102	124	
COARSE SAND	YES	124	128	
COARSE SAND / PEA GRAVEL	YES	128	150	

8. WELL CONSTRUCTION  
 Depth Drilled 150 Feet Depth Cased 150 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
9 Inches 0 Feet 55 Feet  
7 Inches 55 Feet 150 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>-</u>	<u>.198</u>	<u>72</u>	<u>150</u>

Perforations:  
 Type perforation FACTORY SAW SLOT  
 Size perforation 3/32 X 3 8" OC. 5 ROWS  
 From 120 feet to 150 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 24 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 51° °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name EDMUND MILLER DRILLING  
 Address PO Box 92, Smith NV 89430  
 Nevada contractor's license number 32166-A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 2232  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3-25-03

Date started 3-17-03, 19\_\_\_\_\_  
 Date completed 3-24-03, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>32 +/-</u>	<u>8</u>	<u>5</u>