



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50441

1. OWNER David Likes ADDRESS AT WELL LOCATION 1310 Freds Mt Rd
 MAILING ADDRESS P.O. Box 748 Reno, NV 89506
Tahoe City, CA 96195

2. LOCATION NW 1/4 SW 1/4 Sec 27 T 22N N/S R 19 E Washoe County
 PERMIT NO. 079-410-03 Red Rock Estates Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brown Sandy Clays		1	2	1
Weathered granite w/ clay streaks		2	41	39
Rusty granite w/ clay streaks		41	68	27
Weathered granite		68	110	42
Weathered granite w/ clay streaks		110	269	159
White clay		269	273	4
Weathered granite		273	330	57
Weathered granite w/ clay streaks		330	355	25
Gray granite		355	426	71
Soft zone (no water)		426	430	4
Gray granite		430	477	47
Soft zone (no water)		477	485	8
Gray granite		485	555	70
Soft zone (no water)		555	561	6
Gray granite		561	673	112
Fracture granite	X	673	716	43
Gray granite		716	722	6

8. WELL CONSTRUCTION
 Depth Drilled 722 Feet Depth Cased 722 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 Inches	0 Feet 50 Feet
8 5/8 Inches	50 Feet 722 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	722

Perforations:
 Type perforation Factory sawed slot
 Size perforation 3/32 x 3x5

From	feet to
<u>677</u>	<u>717</u>

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50ft

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 722 feet

Date started 6-16-03, 19.....
 Date completed 6-24-03, 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 616 feet below land surface
~~Artesian flow~~ 20 G.P.M. P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling Inc. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV 89510

Nevada contractor's license number 0022549
 issued by the State Contractor's Board.

Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller.

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date 6-25-03

RECEIVED
 03 JUL -8 AM 10:41
 SURVEILLING OFFICE