

Log No. 90403
 Permit No. 37B
 Basin. 37B
 NOTICE OF INTENT NO. 48741

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Round Mt Gold Corp ADDRESS AT WELL LOCATION Smoky Valley Common Operation pit
 MAILING ADDRESS P.O. Box 480
Round Mountain Nevada 89045
 2. LOCATION NE 1/4 NE 1/4 Sec. 30 T 10 R 44 E Nye County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Hard Rock</u>		<u>0</u>	<u>680</u>	<u>680'</u>
<u>Small Fractures</u>		<u>680</u>	<u>800</u>	<u>180'</u>
<u>Hard Rock</u>		<u>800</u>	<u>840</u>	<u>40'</u>
<u>1 1/2 Super Sacks #8 Sand</u>		<u>670</u>	<u>840</u>	<u>170'</u>
<u>125 - 50# Bags 3/8</u>		<u>50</u>	<u>670</u>	<u>620'</u>
<u>Hole plug</u>				
<u>17 - 94# Bags Cement</u>		<u>+3</u>	<u>50</u>	<u>53</u>

8. WELL CONSTRUCTION
 Depth Drilled 840 Feet Depth Cased 800 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 26 Feet
12 1/2 Inches
 From 20 Feet To 840 Feet
6 3/4 Inches
 From _____ Feet To _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>3"</u>		<u>188 wall</u>	<u>+3</u>	<u>20</u>
<u>2"</u>		<u>sch 80 PVC Blank</u>	<u>+3</u>	<u>700</u>
<u>2"</u>		<u>sch 80 PVC Screen</u>	<u>700</u>	<u>800</u>

Perforations:
 Type perforation Mill Cut Horiz
 Size perforation .020
 From 700 feet to 800 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Gravel Packed: Yes No
 From 670 feet to 840 feet

9. WATER LEVEL
 Static water level 310 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Warm °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EKund Drilling Co INC Contractor
 Address P.O. Box 2748 Contractor
Elko, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 0030823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1879
 Signed B. R. Clark
 By driller performing actual drilling on site or contractor
 Date 8-7-03

Date started 7-31, 2003
 Date completed 8-7, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>4</u>	<u>N/A</u>	<u>20 hrs</u>

RECEIVED
 AUG 22 AM 11:34
 WATER RESOURCES OFFICE