WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90405
Permit No.
Basin 071

NOTICE OF INTENT NO. 51199

1. OWNER Jolene Nielsen
MAILING ADDRESS 9350 S. Alice Lane
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 9350 S.Alice Lane

2. LOCATION _____ 1/4 NW 1/4 Sec. 30 T 35N N/S R 38E E Humboldt County
PERMIT NO. _____ Issued by Water Resources | 10-532-12 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other _____

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	x	198	205	
sand & gravel	x	205	271	66

RECEIVED
03 AUG 15 AM 11:20
STATE ENGINEER'S OFFICE

Date started 8/7/03, 19__
Date completed 8/7/03, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 271 Feet Depth Cased 270 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7-7/8 Inches		198 Feet	271 Feet
_____ Inches		_____ Feet	_____ Feet
_____ Inches		_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Well Thickness (Inches)	From (Feet)	To (Feet)
6		.188	185	270

Perforations:
Type perforation mill slot
Size perforation .100
From 185 feet to 270 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal _____
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 W. Winnemucca Blvd
Contractor
Winnemucca, Nevada 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources the on-site driller 2235

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 8/14/03