

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 90410
Permit No. _____
Basin D70

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.170

NOTICE OF INTENT NO 50217

OWNER Maga Living Trust ADDRESS AT WELL LOCATION 4505 W. Winnemucca Blvd.
MAILING ADDRESS 4505 W. Winnemucca Blvd.
Winnemucca, NV 89445

2. LOCATION NE 1/4 SW 1/4 Sec. 2 T 35 N/S R 37 E Humboldt County
PERMIT NO. 69011 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Coarse sand w/cobbles & clay		3	12	9
Coarse sand and gravel		12	41	29
Sand and gravel up to 1 inch		41	89	48
Fine to coarse sand and gravel		89	153	64
Sand and tan clay		153	171	18
Sand and clay, streaks of gravel		171	195	24
Sand and gravel w/some clay		195	216	21
Clay w/sand and gravel		216	236	20
Sandy clay		236	300	64

8. WELL CONSTRUCTION
Depth Drilled ~~240~~ 300 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
From To
15 Inches 0 Feet 240 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 1/2</u>		<u>.250</u>	<u>+2</u>	<u>50</u>

Perforations:
Type perforation Mill Slot and Louvered
Size perforation .090

From 50 feet to 160 Louvered feet
From 160 feet to 240 Mill Slot feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 13 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed [Signature]
By driller performing actual drilling on-site or contractor
Date 3/13/03

Date started 3/4/03, 19____
Date completed 3/11/03, 19____

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>+500</u>		<u>8 Hrs.</u>	