WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90413
Permit No.
Basin 107

NOTICE OF INTENT NO. 27325

1. OWNER F. M. Fulstone
MAILING ADDRESS P.O. Box 34
Smith, NV. 89430

ADDRESS AT WELL LOCATION 2400 Hwy 208
Smith, NV. 89430

2. LOCATION SE NE ¼ SE NE ¼ Sec. 19 OR 20 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. 12275 OR 12276 (Issued by Water Resources) | 10-531-03 (Parcel No.) | F.M. Fulston Ranch / Bed + Breakfast (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sandy		0	3	3
Coarse Sand - Gravel		3	8	5
Coarse Sand - Gravel - Rock		8	16	8
Coarse Sand - Gravel - Clay		16	24	8
Fine To Coarse Sand - Gravel + Clay Stratas	X	24	72	48
Brown Clay - Fine Sand		72	112	40
Coarse Sand - Gravel	X	112	121	9
Coarse Sand - Gravel - Clay - Hard		121	129	8
Brown Clay - Coarse Sand		129	141	12
Fine To Coarse Sand - Small Gravel	X	141	165	24
Brown Clay - Coarse Sand		165	190	25
Coarse Sand - Small Gravel	X	190	207	17
Brown Clay - Coarse Sand		207	218	11
Coarse Sand - Small Gravel Brown Clay		218	234	16
Coarse Sand - Gravel - Clay - Hard		234	320	86
Coarse Sand - Gravel	X	320	339	19
Brown Clay + Coarse Sand - Small Gravel - Hard		339	370	31
Coarse Sand - Brown Clay		370	378	8
Brown Clay - Coarse Sand		378	402	24
Brown Clay - Sand Stratas		402	435	33
Coarse Sand - Gravel	X	435	470	35
Same with Clay Stratas		470	475	5
Sand - Gravel - Few Rock	X	475	480	5

Date started 6-5, 19 2000
Date completed 6-23, 19 2000

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift	50	120' Line	2 HRS
Pumped	55	4	1 HR

8. WELL CONSTRUCTION
Depth Drilled 480 Feet Depth Cased 481 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11 Inches	0 Feet	480 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	20 Steel
6 5/8	4.95	.390	20	480 PVC

Perforations:
Type perforation Sawed - Factory Slots
Size perforation .032 X 5 Rows
From 440 feet to 480 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10' Top 40' Bottom
Placement Method: ☒ Pumped 30% Grout ☐ Poured

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout
☒ 30% Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 480 feet

9. WATER LEVEL
Static water level 56 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DBA Ogden Drilling (Contractor)
Address 152 N. By Bee Ln (Contractor)
Yerington NV 89447

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed [signature]
By driller performing actual drilling on site or contractor
Date 7-30-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627