

6mm-9A

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 907-35
Permit No. 087
Basin. 087

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 16072

1. OWNER Manjeet Sodhi ADDRESS AT WELL LOCATION Gofer Market
 MAILING ADDRESS P.O. Box 33696 4600 N Virginia St
Reno NV 89533 Reno NV 89506

2. LOCATION NW 1/4 SW 1/4 Sec. 26 T. 20 S. R. 19 E. Washoe County

PERMIT NO. 309118 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sands</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Bm. stiff clays</u> <u>white gray seams</u> <u>Dry</u>		<u>2</u>	<u>56</u>	<u>54</u>
<u>Turning moist Brown</u> <u>silty clays + small</u> <u>gravels</u>		<u>56</u>	<u>60</u>	<u>4</u>
<u>Tight reddish bm</u> <u>clay dry</u>		<u>60</u>	<u>70</u>	<u>10</u>

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From _____ To _____
8 Inches 0 Feet 70 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>Sch 40</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation Factory
 Size perforation 1.010
 From 35 feet to 70 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 33

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 33 feet to 70 feet

Date started 9-3 2003
 Date completed 9-3 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Beart Hongear Contractor
 Address P.O. Box 1000 Contractor
Dayton NV

Nevada contractor's license number issued by the State Contractor's Board 0010157
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M. 2222

Signed Beart Hongear
 By driller performing actual drilling on site of contractor
 Date 9-5-03