


PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



NOTICE OF INTENT NO. 46073

1. OWNER Manjeet Sodhi ADDRESS AT WELL LOCATION 4550 Parr Blvd  
 MAILING ADDRESS P.O. Box 33696 Reno NV 89506  
 2. LOCATION NW 1/4 SW 1/4 Sec. 26 T. 20 S R. 19 E. 1st m. Washoe County  
 PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soils/Fill		0	2	2
Bm <del>stiff</del> silty clay with sand & gray layer		2	30	28
Bm silty clay with fines interbedded w/ mudstone		30	40	10
Bm & gray clays stiff moist		40	60	20
Bm with gray seams	65	60	80	20
white clay gravels (small)		80	85	5

8. WELL CONSTRUCTION  
 Depth Drilled 85 Feet Depth Cased 85 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 2" Inches To 0 Feet 85 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Sch 40	0	50

Perforations:  
 Type perforation Factory  
 Size perforation .010  
 From 50 feet to 85 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 48  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 48 feet to 85 feet

Date started 9-4, 2003  
 Date completed 9-5, 2003

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Boart Longyear Contractor  
 Address P.O. Box 1000 Contractor  
Dayton NV 89403  
 Nevada contractor's license number issued by the State Contractor's Board 0010157 AF  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M. 2222  
 Signed Bruce Cleburn  
 By driller performing actual drilling on site or contractor  
 Date 9-5-03