

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



office use only
Log No. 90739
Permit No.
Basin 087

NOTICE OF INTENT NO 48485

1. OWNER **Scott Nahas**
MAILING ADDRESS **12475 Westridge Dr**
Reno NV

ADDRESS AT WELL LOCATION **12475 Westridge Dr**

2. Location **SE 1/4 SE 1/4 Sec 18 T 18N R 20E** **Washoe** County
PERMIT NO. **PARCEL NO. 162-042-02** SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE
 New Well Replace Recondition | Domestic Irrigation Test | Cable Rotary RVC
 Deepen Abandon Other | Municipal/Industrial Monitor Stock | Air Other Mud

6. LITHOLOGIC LOG					8. WELL CONSTRUCTION				
Material	Water Strata	From	To	Thickness	Depth Drilled	HOLE DIAMETER (BIT SIZE)	Depth Cased	HOLE DIAMETER (BIT SIZE)	
Boulders.		0	60	60	12	inches 0	feet 60	feet 60	
Rock & clay.		60	110	50	8 3/4	inches 60	feet 260	feet 260	
Sand & clay.		110	260	150		inches	feet	feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.94	188	+1 1/2	260

Perforations:	
Type Perforation	Factory
Size perforation	3/32 x 3"
From 220 feet to 260 feet	
From feet to feet	
From feet to feet	
From feet to feet	
From feet to feet	

Surface Seal		Seal Type:	
X YES	No	Neat Cement	
Depth of Seal 50 feet		X Cement Grout	
	Pumped	Concrete Grout	
	x Poured		

9. WATER LEVEL			
Static water level	120	feet below land surface	
Artesian flow	0	GPM	0 P.S.I.
Water Temperature	cold	Degrees F	Quality

COPIED 4/10/03
 WASHOE COUNTY OFFICE

Date started **4-24 -03**
Date completed **4-29 -03**

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	x	Air Lift
G.P.M.	Draw Down (Feet Below Static)			Time (hours)
15	55			.5
35	80			1
50	140			2

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509

NV Contractors No. **14170**
NV Driller's Lic (on site) **786**

Signed

By driller performing actual drilling on site or contractor

Date **5-1 -03**