

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 70440
 Permit No. _____
 Basin 107

NOTICE OF INTENT NO. 47916

1. OWNER RICHARD + BERTINA DE PAZ ADDRESS AT WELL LOCATION COPPER BELT RD. SMITH NV 89430
 MAILING ADDRESS 374 EL PORTAL WAY SAN JOSE CA. 95123

2. LOCATION SE 1/4 SE 1/4 Sec. 13 T. 11 N R. 24 E LYON County _____
 PERMIT NO. NONE 10-471-09 Issued by Water Resources Parcel No. _____ Subdivision Name NONE

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND + GRAVEL	-	0	25	25
SANDY BWN CLAY	-	25	35	10
CEMENTED GRAVEL	-	35	40	5
COARSE SAND + BWN CLAY	-	40	65	25
SANDY BWN CLAY	-	65	135	50
COARSE SAND + GRAVEL	YES	135	160	25

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 5.5 Feet
7 Inches 55 Feet 160 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>-</u>	<u>.188</u>	<u>41.5</u>	<u>160</u>

Perforations:
 Type perforation FACTORY SAW SLOT
 Size perforation 1/8" X 3 X 8" OC. 6 ROWS
 From 130 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 5.5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 5.5 feet below land surface
 Artesian flow -NO- G.P.M. _____ P.S.I. _____
 Water temperature COLD °F Quality EXELEN

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDMUND MILLER DRILLING Contractor
 Address PO BOX 912 SMITH NV 89430 Contractor

Date started APRIL 29 03, 19_____
 Date completed MAY 9 03, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>BALE</u>	<u>50 +/-</u>	<u>5 +/-</u>	<u>4</u>
<u>PUMP</u>	<u>25</u>	<u>0</u>	<u>3</u>

Nevada contractor's license number 32166-A issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
 Signed Edmund Miller
 By driller performing actual drilling on site or contractor
 Date MAY 12 03