WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 10443
Permit No.
Basin 108

NOTICE OF INTENT NO. 53348

1. OWNER Nevada Dept of Agriculture
MAILING ADDRESS 350 Capital Hill Avenue Reno Nv 89502
ADDRESS AT WELL LOCATION City of Yerington Mountain View Municipal Well. Corner of Mountain View + Van Ness St.

2. LOCATION NE ¼ NW ¼ Sec. 15 T. 13 N/S R. 25 E. Lyon County
PERMIT NO. MO-1286 (Issued by Water Resources) | 001-301-004 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface Soil + Angular		0	1	1
Rock, Road Bed Fill		~~1~~	~~2.5~~	
Slightly moist Black		1	2.5	1.5
Silty Clay				
Black Clayey Loam		2.5	3.5	1.0
Brown Fine Silty Sand		3.5	6.5	3.0
Brown Fine Sand		6.5	10.5	4.0
Brown Gravelly Sand 1/2"	X	10.5	12.5	2.0
Brown Coarse Sand	X	12.5	15.6	3.1

Date started Sept 8, 2003
Date completed Sept 8, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
0.5		1.25

8. WELL CONSTRUCTION
Depth Drilled 15.6 Feet Depth Cased 15.6 Feet

HOLE DIAMETER (BIT SIZE)
6.625 Inches From 0 Feet To 15.6 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.0		Sched 40	0	15.6

Perforations:
Type perforation MACHINED SLOT
Size perforation 0.01"
From 10.1 feet to 15.1 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 9
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 9 feet to 15.6 feet

9. WATER LEVEL
Static water level 10.68 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name USGS HF
Contractor
Address 333 W. Nye Ln.
Contractor
C.C. NV 89706
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP-2178
Signed [signature]
By driller performing actual drilling on site or contractor
Date 9/22/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627



ALT 95
4377 T
Municipal Airport
4378 T
Rodeo Ground
Weir
Weir
Weir
Trailer Park
339
Athletic
Fields
4380
Rondside Park
Weir
Elevated
Park
Yerington
P.O.
Park
BM
208
WT
4384
Elevated
Well
Well
BR
4398 T
Hosp
4391 T
340
4389 T
4386 T
BM 4383
TP
TP
TP
4387AT
DITCH
6-128
4392 T
FOX
Well
BM 4396
4402 T
Golf Course
MAIN
Cem
Ditch
27
26
4403 T
4408 T
4407 T
HALL
DITCH
Well
DITCH
Well
4408 T
4410 T
4411 T
4408 T
FOX
BM



30' NORTH OF MUNICIPAL WELL
30' WEST OF MOUNTAIN VIEW ST.