PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Permit No. 90452
Basin 101

NOTICE OF INTENT NO. 49196

1. OWNER GARY RAU
MAILING ADDRESS 4805 LARIAT
FALLON, NV 89406

ADDRESS AT WELL LOCATION 4805 LARIAT

2. LOCATION SW 1/4 NE 1/4 Sec. 16 T 18 N/S R 28 E CHURCHILL County
PERMIT NO. (Issued by Water Resources) | 006-171-35 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	
BROWN SAND		1	13	12
BROWN CLAY		13	18	5
BROWN SAND		18	30	12
BROWN CLAY		30	32	2
BROWN CLAY		32	75	43
BROWN CLAY		75	85	10
GREY SAND		85	120	35
GREY CLAY		120	122	2
GREY SAND		122	135	13
GREY CLAY		135	140	5
BROWN SAND	X	140	152	12

RECEIVED
2003 AUG 1 PM 12:50
ENGINEERING OFFICE

Date started 7/25/1903 2003, 19__
Date completed 7/25/1903 2003, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1HR

8. WELL CONSTRUCTION

Depth Drilled 152 Feet Depth Cased 152 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	100	Feet
6 5/8	Inches	100	Feet	152	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	152

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 145 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 20'3" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WELSCO CORP. Contractor
Address P. O. BOX 888 Contractor
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed By driller performing actual drilling on-site or contractor
Date 8/7/2003

USE ADDITIONAL SHEETS IF NECESSARY