WASHOE # WL30155

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 90455
Permit No.
Basin 099

NOTICE OF INTENT NO 49114

OWNER Laura Cunningham
MAILING ADDRESS 15775 Panhandle Rd
Reno NV

ADDRESS AT WELL LOCATION 15775 Panhandle Rd

2. Location SE 1/4 SE 1/4 Sec 11 T 23N R 18E Washoe County
PERMIT NO. PARCEL N0. 078-182-04 SUBDIVISION NAME

---

3. WORK PERFORMED

x New Well | Replace | Recondition
Deepen | Abandon | Other

4. PROPOSED USE

X Domestic | Irrigation | Test
Municipal/Industrial | Monitor | Stock

5. WELL TYPE

Cable | X Rotary | RVC
Air | Other | X Mud

---

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG		0	180	180
				0
Installed cement plug				0
170-to180				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0
				0

03 SEP 10 AM 11:03
STATE ENGINEERS OFFICE

Date started 7-31 -03
Date completed 8-7 -03

7. WELL TEST DATA

TEST METHOD: Bailer | Pump | x Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (hours)
50	50	.5
80	100	.5
100	170	.5

8. WELL CONSTRUCTION

Depth Drilled 180 feet Depth Cased 180 feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	inches	0	feet	180	feet
	inches		feet		feet
	inches		feet		feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To Feet
6 5/8	12.94	188	+1 1/2	180

Perforations::
Type Perforation Factory
Size perforation 3/32 x 3"
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal X YES No
Depth of Seal 80 feet
x Pumped
Poured

Seal Type:
Neat Cement
x Cement Grout
Concrete Grout

Gravel Packed: Yes x No
From 80 feet to 180 feet

---

9 WATER LEVEL

Static water leve0 feet below land surface
Artesian flow 8 GPM 2 P.S.I.
Water Temperature cold Degrees F Quality

---

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name McKay Drilling, Inc.
2290 Pioneer Drive
Reno, NV 89509

NV Contractors No. 14170
NV Driller's Lic (on site) 786

Signed [signature]
By driller performing actual drilling on site or contractor

Date 8-11 -03