

MW-8

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 90502

Permit No. \_\_\_\_\_

Basin. 105



PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 46069

1. OWNER Verizon Services Group ADDRESS AT WELL LOCATION Less than 1 mile Past Hwy. 208 on 395, Fire Rd. on right side, Dirt road to top of hill, 2 1/2 miles

MAILING ADDRESS P.O. Box 725 Chino, Ca. 91708

2. LOCATION NW 1/4 NE 1/4 Sec. 23 T. 10N @ S R. 21E @ Douglas County

PERMIT NO. 1021.00.001.070

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Back Filled with Bentonite Chips</u>		<u>20'</u>	<u>109'</u>	<u>89'</u>
<u>Back Filled with Concrete Grout</u>		<u>0'</u>	<u>20'</u>	<u>20'</u>
<u>Back Filled hole and then removed top 5' of P.V.C. and steel casing.</u>				

8. WELL CONSTRUCTION

Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

From	To
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4" (P.V.C.)</u>		<u>sch. 80 P.V.C.</u>	<u>0'</u>	<u>29'</u>

Perforations:  
 Type perforation Factory Cut  
 Size perforation Information Unavailable

From 29' feet to 109' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 03 AUG -5 AM 10:41  
 STATE ENGINEERS OFFICE

Date started 7-25-03, 19\_\_\_\_  
 Date completed 7-25-03, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL

Static water level: 104.80 feet below land surface

Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Phillip Cramer Contractor Boart Longyear

Address P.O. Box 1000 Dayton, Nv. 89403 Contractor

Nevada contractor's license number issued by the State Contractor's Board: 0010157

Nevada driller's license number issued by the Division of Water Resources, the on-site driller: M-2148

Signed Phillip E. Cramer  
 By driller performing actual drilling on site or contractor

Date 7-29-03