MW-2

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 905 06
Permit No.
Basin 105

NOTICE OF INTENT NO. 46070

1. OWNER Verizon Services Group
MAILING ADDRESS P.O. Box 725
China, CA. 91708

ADDRESS AT WELL LOCATION less than 1 mile Past Hwy. 208 on 395, Fire Road on Right Side, Dirt Road to Top of hill 2½ miles.

2. LOCATION NW ¼ NE ¼ Sec. 23 T. 10N (N)/S R. 21E (E) Douglas County
PERMIT NO. Issued by Water Resources | 1021 00 001 070 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BackFilled with Bentonite Chips		20'	119'	99'
BackFilled with Concrete Grout		0'	20'	20'
BackFilled hole and removed top 5' of P.V.C. and then removed Flushmount Vault				

RECEIVED
03 AUG -5 AM 10:40
STATE ENGINEERS OFFICE

Date started 7-23-03, 19
Date completed 7-23-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch.80 P.V.C.	0'	39'

Perforations:
Type perforation Factory Cut
Size perforation unavailable Information
From 39' feet to 119' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 114.30 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Phillip Cramer Contractor Bart Longyear
Address P.O. Box 1000 Dayton, Nv. 89403 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148
Signed Phillip E. Cramer By driller performing actual drilling on site or contractor
Date 7-29-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627