

MW-6

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 90509

Permit No. _____

Basin 105



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46070

1. OWNER Verizon Services Group ADDRESS AT WELL LOCATION less than 1 mile Past Hwy. 208 on 375, Fire Rd. on right Side, Dirt road to top of hill, 2 1/2 miles

MAILING ADDRESS P.O. Box 725 China, Ca 91708

2. LOCATION NW 1/4 NE 1/4 Sec. 23 T. 10 N 21 E Douglas County

PERMIT NO. 1001.00.001.070

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED

New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE

Domestic Municipal/Industrial Irrigation Test Monitor Stock

5. WELL TYPE

Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Back Filled with Bentonite Chips</u>		<u>20'</u>	<u>102'</u>	<u>82'</u>
<u>Back Filled with Concrete Grout</u>		<u>0'</u>	<u>20'</u>	<u>20'</u>
<u>Back Filled hole and then removed Flush-mount Vault.</u>				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From _____ To _____

Inches _____ Feet _____

Inches _____ Feet _____

Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>21.80 P.U.C.</u>	<u>22'</u>	<u>102'</u>
			<u>0'</u>	<u>22'</u>

Perforations:

Type perforation Factory Cut

Size perforation Information not available

From 22' feet to 102' feet

From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout

Depth of Seal _____

Placement Method: Pumped Poured

Gravel Packed: Yes No

From _____ feet to _____ feet

9. WATER LEVEL

Static water level 99.80 feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Phillip Cramer Contractor Boalt Longyear

Address P.O. Box 1000 Dayton, Nv. 89403

Nevada contractor's license number issued by the State Contractor's Board 0010157

Nevada driller's license number issued by the Division of Water Resources, the on-site driller: M-2148

Signed Phillip E. Cramer By driller performing actual drilling on site or contractor

Date 7-29-03

Date started 7-24-03, 19____

Date completed 7-24-03, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
03 AUG -5 AM 10:40
STATE ENGINEERS OFFICE