

MW-9

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 90511
Permit No. _____
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 46070

1. OWNER Verizon Services Group
MAILING ADDRESS P.O. Box 725
Chino, Ca. 91708
ADDRESS AT WELL LOCATION less than 1 mile Past Hwy. 208 on 395, Fire Rd. on Right Side, Dirt road to top of hill, 2 1/2 miles
2. LOCATION NW 1/4 NE 1/4 Sec. 23 T. 10N S. R. 21 E Douglas County
PERMIT NO. 1021 00 001 070
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Backfilled with bentonite chips</u>		<u>20'</u>	<u>108'</u>	<u>88'</u>
<u>Backfilled with concrete grout</u>		<u>0'</u>	<u>20'</u>	<u>20'</u>
<u>Backfilled hole, and then removed Flush Mount Vault</u>				

8. WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased _____ Feet
HOLE DIAMETER (BIT SIZE)
From _____ To _____
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>sch. 80 P.V.C.</u>	<u>0'</u>	<u>28'</u>

Perforations:
Type perforation Factory Cut
Size perforation Information is unavailable
From 28' feet to 108' feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
Depth of Seal _____
Placement Method: Pumped Poured
Gravel Packed: Yes No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level: 100.00 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 7-28-03
Date completed 7-28-03

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Phillip Cramer Contractor Boast Langyear
Address P.O. Box 1000 Dayton, Nv. 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2148
Signed Phillip E. Cramer
By driller performing actual drilling on site or contractor
Date 7-29-03

RECEIVED
03 AUG -5 AM 10:40
STATE ENGINEERS OFFICE