

OFFICE USE ONLY
 Log No. 90574
 Permit No.
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47960
 1231 Golden Eagle Ct.
 GARDNERVILLE, NV 89410

1. OWNER Ram Builders Inc. ADDRESS AT WELL LOCATION 1231 Golden Eagle Ct. Gardnerville, NV 89410
 MAILING ADDRESS 2541 Henning Ln Gardnerville NV 89410
 2. LOCATION NW 1/4 SW 1/4 Sec. 01 T. 12 S. R. 20 E. Douglas County
 PERMIT NO. 122001002041 STERLING RANCH ESTATES
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SOIL gravel clay		0	5	5
Hard pan		5	9	4
gravel sand sm cobbles		9	60	51
CLAY		60	70	10
SAND gravel sm. COBBLES		70	105	35
clay		105	115	10
SAND gravel sm COBBLES		115	145	30
clay		145	160	15
SAND GRAVEL sm COBB. (X)		160	172	12
clay		172	195	
SAND gravel sm COBB (X)		195	240	

380 55. 852 W
 1190 41. 601 W 4997' elev.

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 240 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	200
		.188		

Perforations:
 Type perforation factory slot
 Size perforation 3/32 x 3"
 From _____ feet to _____ feet
 From 200 feet to 240 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 122 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality _____

Date started 6-30
 Date completed 7-3 (1903)

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60+</u>		<u>2.5 hours +</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Nevada Drilling + Pump LLC Contractor
 Address 3540 Green Acres Dr Carson City NV 89705 Contractor
 Nevada contractor's license number 52078 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on site driller: 1902
 Signed John B. David
 By driller performing actual drilling on site or contractor
 Date 7-3-03