WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90515
Permit No.
Basin 104

NOTICE OF INTENT NO. 42238

1. OWNER Phyllis Gruenwald
MAILING ADDRESS 1033 East Appion Way
Carson City, NV 89701

ADDRESS AT WELL LOCATION 1033 East Appion Way,
Carson City NV.

2. LOCATION SW 1/4 NE 1/4 Sec. 32 T 15 N/S R 20 E Carson City County
PERMIT NO. Issued by Water Resources | 9-214-01 Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 126' of drop pipe and pump from well. Measured static water level at 58'. Measured depth of well at 158'. Installed 2" tremme pipe and blew debris from well until we hit hard bottom at 160'. Installed mills knife and perforated 4 rows per foot from 136' to 42' where we could no longer perforate casing because of cement seal. We then installed 157' of 2" tremme pipe and mixed 50 bags of cement with 250 gallons of water and pumped in from bottom of well to surface. Casing was then cut off 1' below ground level.				

Date started 06/26/2003, 19__
Date completed 06/26/2003, 19__

RECEIVED 03 JUL 14 PM 12:55 STATE ENGINEERS OFFICE

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased 160' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.188	+2	160'

Perforations:
Type perforation Mills knife
Size perforation
From 136' feet to 42' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 160'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 58' feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump (Contractor)
Address P.O. Box 20159 (Contractor)
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 07/11/2003

USE ADDITIONAL SHEETS IF NECESSARY