

OFFICE USE ONLY  
 Log No. 905195  
 Permit No. \_\_\_\_\_  
 Basin 051

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51137

1. OWNER Newmont Pete ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO Box 669 Pete - 16  
Carlin, Nevada 89822  
 2. LOCATION NE 1/4 SE 1/4 Sec 13 T. 35 (N) R. 50 (E) Eureka County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Materials used:				
28 Gallons Super Plug				
5 Gallons Portland Cement 20' plug				
1/2 - 50lbs Bag Super Plug				
1 - 94lbs Bag Portland Cement				

8. WELL CONSTRUCTION  
 Depth Drilled 135 Feet Depth Cased 135 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>20.37</u>			<u>0</u>	<u>135</u>

 Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From 115 feet to 135 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 60'  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 100' feet to 135' feet

Date started August 9, 2003, 20.....  
 Date completed August 9, 2003, 20.....

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level Dry feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SKLund Drilling Contractor  
 Address PO Box 2748 Contractor  
SKLU, Nevada 89803  
 Nevada contractor's license number issued by the State Contractor's Board 0030823  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2100  
 Signed Shawn A. Jantz  
 By driller performing actual drilling on site or contractor  
 Date 8-9-03

RECEIVED  
 AUG 19 AM 10:21  
 ENGINEERS OFFICE