

OFFICE USE ONLY
 Log No. 90601
 Permit No. _____
 Basin. 051

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51134

1. OWNER Newmont Pete ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS PO Box 669 Pete-03
Carlin, Nevada 89822
 2. LOCATION NE 1/4 NE 1/4 Sec 24 T 35 N R 50 E SUNDA County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Materials used</u>				
<u>33 1/2 Gallons Super Plug</u>				
<u>102 11 Portland Cement</u>				
<u>74 - 50lbs bag Super Plug</u>				
<u>14 - 94lbs bag Portland Cement 20' plug</u>				

8. WELL CONSTRUCTION
 Depth Drilled 350 Feet Depth Cased 330 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>1.25</u>				

Perforations:
 Type perforation _____
 Size perforation _____
 From 330 feet to 350 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 325 feet to 350 feet

RECEIVED
 13 AUG 19 AM 10:21
 STATE ENGINEERS OFFICE

Date started August 9, 2003, 19____
 Date completed August 9, 2003, 19____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level Any feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eklund Drilling Contractor
 Address PO Box 2748 Contractor
EIKO, Nevada 89803
 Nevada contractor's license number 0030823
 issued by the State Contractor's Board
 Nevada driller's license number issued by the M2100
 Division of Water Resources, the on-site driller
 Signed Shawn A. Taylor
 By driller performing actual drilling on site or contractor
 Date 8-9-03