

OFFICE USE ONLY  
 Log No. 90696  
 Permit No. 073  
 Basin  
 NOTICE OF INTENT NO. 50007

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Time Oil Co ADDRESS AT WELL LOCATION 3055 Cornell St  
 MAILING ADDRESS 2737 W. Commodore Way Seattle WA 98199 LoveLack NV  
 2. LOCATION SE 1/4 SE 1/4 Sec. 27 T. 27 N. R. 31 E Perishing County  
 PERMIT NO. Jackpot Food Mart Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thick-ness
SEE ATTACHED				

8. WELL CONSTRUCTION  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 4-16-03, 19\_\_\_\_  
 Date completed 4-16-03, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Cascade Drilling Inc Contractor  
 Address 3632 Omega Circle Contractor  
Rancho Cordova CA 95742  
 Nevada contractor's license number C23-51207  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the m-1977  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 by driller performing actual drilling on site or contractor  
 Date 5-29-03



**CASCADE DRILLING, INC.**

C A L I F O R N I A  
STATE CONTRACTOR'S  
LICENSE # 057-717510

**SACRAMENTO**

3632 Omeo Circle  
Rancho Cordova, CA 95742  
(916) 638-1169 PH  
(916) 638-5611 FAX

June 25, 2003

**Tim Hunt**

State of Nevada  
Division of Water Resources  
123 W. Nye Lane, Suite 246  
Carson City, NV 89706

RE: Jackpot Food Mart  
365 Cornell Street, Lovelock, Nevada

Dear Mr. Hunt:

Below is the breakdown on the plugging and abandoning of 8 wells by pressure grouting at the above referenced project.

MW-1: 24', 2" well used 3 bags of grout, 25 lbs of pressure for 2 minutes.

MW-2: 22', 4" well used 4 bags of grout, 25 lbs of pressure for 2 minutes.

MW-3: 22', 4" well used 4 bags of grout, 25 lbs of pressure for 2 minutes.

MW-4: 24', 2" well used 3 bags of grout, 25 lbs of pressure for 2 minutes.

MW-5: 24', 2" well used 3 bags of grout, 25 lbs of pressure for 2 minutes.

MW-6: 22', 2" well used 3 bags of grout, 25 lbs of pressure for 2 minutes.

MW-7: 22', 2" well used 3 bags of grout, 25 lbs of pressure for 2 minutes.

MW-8: 22', 2" well used 3 bags of grout, 25 lbs of pressure for 2 minutes.

Sincerely,

Vera Chapman  
Operations Manager

VC/cc

**LOS ANGELES**

11250 E. Firestone Blvd.  
Norwalk, CA 90650  
(562) 929-8176 PH  
(562) 863-9534 FAX

**SEATTLE**

P.O. Box 1184  
Woodinville, WA 98072  
(425) 485-8908 PH  
(425) 485-4368 FAX

**PORTLAND**

6400 SE 101st Ave., Ste. 2-D  
Portland, OR 97266  
(503) 775-4118 PH  
(503) 775-4099 FAX