

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 90701
 Permit No. 59195T
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **51509**

1. OWNER **Barrick Goldstrike Mines** EW-151 ADDRESS AT WELL LOCATION **Barrick Goldstrike**
 MAILING ADDRESS **P.O. Box 29** minesite north of Carlin, NV.
Elko, NV 89803

2. LOCATION SE 1/4 SE 1/4 Sec. 19 T 36N N/S R 50 E **Eureka** County
 PERMIT NO. 59195-T Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
+Note: Upper 303' has been mined off.				
Construction data given do not take this into account.				
Prior to abandoning the well, fill was removed by drilling. Abandoned by pumping abantonite via tremie from T.D. to 609', then poured hole plug while pumping abantonite to 20', and capped with neat cement.				
Quantities Used:				
Cement: 18 cu.ft.				
Hole plug: 150 cu.ft.				
Abantonite: 499 cu.ft.				

Date started 8/19/2003 . 19
 Date completed 8/22/2003 . 19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

8. WELL CONSTRUCTION
 Depth Drilled 1200 Feet Depth Cased 1190 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>36</u>	<u>0</u>	<u>45</u>	<u>1200</u>	
<u>17.5</u>	<u>45</u>	<u>1200</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>20</u>	<u>78.6</u>	<u>0.375</u>	<u>0</u>	<u>44</u>
<u>12</u>	<u>33.38</u>	<u>0.250</u>	<u>0</u>	<u>1190</u>

Perforations:
 Type perforation Louver
 Size perforation 0.125"

From	feet to	feet
	<u>188</u>	<u>228</u>
	<u>308</u>	<u>348</u>
	<u>428</u>	<u>468</u>
	<u>688</u>	<u>1190</u>

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 1200 feet

9. WATER LEVEL
 Static water level 560 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2039
 Signed Dennis Bobblee
 By driller performing actual drilling on-site or contractor
 Date 8/26/03

BSTL