

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 90705
 Permit No. 55149
 Basin 061

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **48598**

1. OWNER Barrick Goldstrike Mines (BW-38) ADDRESS AT WELL LOCATION Barrick Goldstrike
 MAILING ADDRESS P.O. Box 29 minesite, north of Carlin, NV.
Elko, NV 89803

2. LOCATION SE 1/4 NE 1/4 Sec. 23 T 36N N/S R 49E E Eureka County
 PERMIT NO. 55149 Issued by Water Resources Parcel No. N/A Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
This report is being submitted to document the status of the "well" as of 7/31/03. Per Mr. Tom Gallagher's letter of 7/30/03, the hole is not being fully completed as a well at this time, due to the hole not containing sufficient amounts of water. A steel plate has been tack welded to the 34" casing at surface. Static water level has been estimated from air pressure.				
Alluvium		0	430	430
Siliceous mudstones		430	1350	920
Black limestones		1350	1650	300
Black and gray mudstones		1650	2857	1207

Date started 6/4/2003 19
 Date completed 7/24/2003 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION

Depth Drilled 2857 Feet Depth Cased 433 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
46	0	80	80
38	80	433	433
31	433	2857	2857

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
40	210.93	0.5000	0	80
34	156.82	0.4375	+2	433

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 433' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 1450 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature 87 °F Quality Fair

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1796
 Signed Ron Behreandt
 By driller performing actual drilling on-site or contractor
 Date 7/31/03

RECEIVED
 AUG -4 AM 11:32
 STATE ENGINEERS OFFICE

B.S.T.L