WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90726
Permit No.
Basin 052A

NOTICE OF INTENT NO. 48777

1. OWNER Carol Snee
MAILING ADDRESS 100 Boron Rd.
Reno, NV 89506

ADDRESS AT WELL LOCATION ~~100 Boron Rd.~~ 1305 American Flat Rd

2. LOCATION NE 1/4 NW 1/4 Sec. 4 T 21N N/S R 19E E Washoe County
PERMIT NO. Issued by Water Resources
079-430-04 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granit		0	160	160
Granite salt and pepper		160	340	180
Granite fractured		340	480	140
Granite fractured	X	480	540	60

Washoe County Well Permit # WL 030142

RECEIVED 03 AUG 11 PM 12:53 STATE ENGINEERS OFFICE

Date started 7/31/2003, 19__
Date completed 8/4/2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		3

8. WELL CONSTRUCTION
Depth Drilled 540 Feet Depth Cased 540 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	60	Feet
9 7/8	Inches	60	Feet	540	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	540

Perforations:
Type perforation Machine Cut
Size perforation 3/32 X 3
From 480 feet to 540 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 63'
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 63 feet to 540 feet

9. WATER LEVEL
Static water level 264 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not Tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 8/6/03

USE ADDITIONAL SHEETS IF NECESSARY