


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
 Log No. 90728  
 Permit No. 56717  
 Basin 057  
  
 48762

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO.

1. OWNER  Joan Weinrich ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS HC 61 Box 159 Antelope Valley \_\_\_\_\_  
 Battle Mountain, NV 89820 Battle Mountain, nv 89820  
 2. LOCATION SW 1/4 NW 1/4 Sec. 3 T 24 N/R 41 E Lander County  
 PERMIT NO. 56717  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel & Sand		0	70	70
Brown Clay		70	81	11
Gravel	XX	81	125	44
Brown Clay		125	150	25
Gravel	XX	150	170	20
Brown Clay		170	189	19
Gravel	XX	189	195	6
Brown Clay		195	203	8
Gravel w/Clay Stringers		203	220	17
Brown Clay		220	244	24
Gravel	XX	244	250	6
Brown Clay		250	253	3
Gravel	XX	253	265	12
Brown Clay		265	287	22
Gravel	XX	287	295	8
Clay		295	310	15
Gravel	XX	310	325	15
Clay		325	330	5
Gravel & Sand	XX	330	340	10
Clay		340	390	50
Hard Silty Clay		390	418	28
Brown Clay		418	525	107

8. WELL CONSTRUCTION  
 Depth Drilled 525 Feet Depth Cased 525 Feet  
 HOLE DIAMETER (BIT SIZE)  

Inches	From Feet	To Feet
36	0	50
26	50	525

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30	20.75	.065	0	50
16	42.00	.250	0	525

Perforations:  
 Type perforation mill cut  
 Size perforation 1/4"  
 From 200 feet to 525 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 0 feet to 525 feet

9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1753  
 Signed Wayne Parsons  
 By driller performing actual drilling on-site or contractor  
 Date 7/14/03

Date started 7/27/03, 19\_\_\_\_  
 Date completed 7/1/03, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
Customer Did Own Pump Test			

RECEIVED  
 03 JUL 15 AM 11:03  
 STATE ENGINEERS OFFICE