COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90780
Permit No.
Basin 105
NOTICE OF INTENT NO. 49453

1. OWNER GARY SMITH
MAILING ADDRESS GARDNERVILLE, NV 89410
ADDRESS AT WELL LOCATION 640 MEGAN CT. GARDNERVILLE, NV 89410

2. LOCATION SW ¼ SW ¼ Sec 19 T 12 N R 21 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No. 1221-19-002-021 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
HARD PAN CLAY		0	6	6
COBBLES AND CLAY AND GRAVELS		6	78	72
BROWN CLAY		78	112	34
COURSE GRAVELS		112	215	103
BROWN CLAY SEAMS		215	255	40
FRACTURED GRAVELS AND CLAY SEAMS	XXX	255	300	45

RECEIVED 03 AUG 13 AM 10:47 STATE ENGINEERS OFFICE

Date started 7/11, 20 03
Date completed 7/15, 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	85	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 300' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	300 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	300

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 55' feet to 300 feet

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 142 feet below land surface
Artesian flow G.P.M 20 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP INC. (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 7/24/03

(Rev 3-91) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · Dallas, Texas · (214) 340-9429