WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 40763
Permit No.
Basin Ø44

NOTICE OF INTENT NO. 40218

1. OWNER AngloGold Jerritt Canyon
MAILING ADDRESS HC-31 Box 78 ELKO, NV, 89801
ADDRESS AT WELL LOCATION AngloGold Jerritt Canyon HC-31 Box 78 ELKO, NV, 89801 Jerritt Canyon Mine

2. LOCATION NW ¼ NW ¼ Sec. 17 T. 40 N/S R. 54 E. ELKO County

PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE injection
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Snow Canyon		0	300'	300'
Roberts Mtn.		300'	600'	300'
Hanson Creek #1		600'	680'	80'
Hanson Creek #2		680'	725'	45'
Hanson Creek #3		725'	1035'	310'
Hanson Creek #4		1035	1055'	20'
600' - 5 GPM				
680' - 30 GPM				
817' - 40 GPM				
900' - 50 GPM				
1020' - 60 GPM				
1055' - 80 GPM				
PLUGGED BY				
WELL LOG				
# 112240				
Flush Joint Steel				
Casing				

Date started May 15th 2003
Date completed May 24th 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
41.3622	27°N		
115.9230	43°W		
NA	27 (F2)		

8. WELL CONSTRUCTION
Depth Drilled 1055' Feet Depth Cased 1050' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10"	Inches	0'	Feet	20'	Feet
8½"	Inches	20'	Feet	1055'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	11.35	.25	0'	1050'

Perforations:
Type perforation Slot - Vert.
Size perforation .182
From 1050' feet to 650' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 520'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 441' feet below land surface
Artesian flow 80 G.P.M. 200 P.S.I.
Water temperature 56° °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ward Weaver (Contractor)
Address 2305 Last Chance Rd. ELKO, NV, 89801 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0030630
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1676
Signed Ward Weaver (By driller performing actual drilling on site or contractor)
Date May 24th 2003

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627