WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90771
Permit No.
Basin 108

NOTICE OF INTENT NO. 45652

1. OWNER Roger Benson
MAILING ADDRESS 1945 N. Carson St. Suite 566 Carson City, NV 89701
ADDRESS AT WELL LOCATION 83 Locust dR. Yerington, NV 89447

2. LOCATION SE ¼ SE ¼ Sec. 6 T. 13 N/S R. 25 E. Lyon Hf County
PERMIT NO. — Issued by Water Resources | 04-153-06 Parcel No. | — Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil - Sand				
Gravel - Few Rock		0	3	3
Hard Pan		3	4	1
Alavia Fill - Coarse		4	26	22
Sand + Gravel				
Alavia Fill - Clay w/		26	48	22
Coarse Sand + Few Rock				
Alavia Fill - Coarse		48	72	24
Sand + Gravel				
Alavia Fill - Coarse		72	104	32
Sand - Gravel + Clay				
Alavia Fill - Clay -		104	128	24
Coarse Sand + Gravel				
Alavia Fill - Coarse	X	128	158	30
Sand - Gravel + Few Rock				
Alavia Fill - Coarse Sand		158	175	17
Gravel + Clay				
Alavia Fill - Coarse Sand	X	175	188	13
Gravel + Few Rock				
Alavia Fill - Coarse	X	188	215	27
Sand + Gravel				
Alavia Fill - Coarse	X			
Sand - Gravel + Rock		215	220	5

Date started 4-3, 2002
Date completed 4-12, 2002

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air LIFT	30	190' Air Line	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 221 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 2 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+1	19
6 5/8	APT.	.280	19	20
6 5/8	PVC 4.06	SDR21 .316	20	220

Perforations:
Type perforation Sawed .035
Size perforation .035 X 2" X 5 Rows
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 220 feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
10' ☒ Concrete Grout
30% Grout Bentonite

9. WATER LEVEL
Static water level 132 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling Contractor
Address P.O. Box 92 Contractor
Smith, NV 89430
Nevada contractor's license number issued by the State Contractor's Board 32166 A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
Signed [signature]
By driller performing actual drilling on site or contractor
Date 10-16-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627