WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

I

OFFICE USE ONLY
Log No. 90772
Permit No.
Basin 107

NOTICE OF INTENT NO. 47914

1. OWNER JERRY ATTOWAY
MAILING ADDRESS 3172 KAUCHER
SAN JOSE CA 95127

ADDRESS AT WELL LOCATION ARTESIA ROAD

2. LOCATION NE ¼ SE ¼ Sec. 21 T. 12 N. ~~N/S~~ R. 23 E. LYON County

PERMIT NO. ____ Issued by Water Resources | 10-081-23 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL	NO	0	3	3
SANDY LOAM	NO	3	35	32
SM. GRAVEL/BWN CLAY	NO	35	38	3
SANDY BWN CLAY	NO	38	85	47
HARD DRY BROWN CLAY	NO	85	97	12
COARSE SAND	YES	97	102	5
SANDY BWN CLAY/PEA GRAVEL	YES	102	115	13
SANDY BWN CLAY	YES	115	137	22
COARSE SAND/1" DIA GRAVEL	YES	137	142	5
HARD DRY BWN CLAY/PEA GR.	NO	142	144	2
SANDY BWN CLAY	YES	144	165	21
COARSE SAND/GRAVEL	YES	165	190	25
COARSE SAND	YES	190	205	15
COARSE SAND/GRAVEL	YES	205	220	15

RECEIVED
03 JUN 13 AM 11:17
STATE ENGINEERS OFFICE

Date started MARCH 15TH 2003 19
Date completed MARCH 20TH 2003 19

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ~~[illegible]~~ 220 Feet Depth Cased ~~[illegible]~~ 220 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 5/8 Inches	0 Feet	60 Feet
~~[illegible]~~ Inches	~~[illegible]~~ Feet	~~[illegible]~~ Feet
6 5/8 Inches	60 Feet	220 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.188	+1.5	190

Perforations:
Type perforation FACT. SAW SLOT
Size perforation 1/8" X 4" X 4" OC 4 ROWS
From ~~[illegible]~~ feet to ~~[illegible]~~ feet
From 180 feet to 220 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 70' feet below land surface
Artesian flow NO ~~G.P.M.~~ ~~P.S.I.~~
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDMUND MILLER DRILLING
Contractor
Address PO BOX 92 SMITH NV. 89430
Contractor

Nevada contractor's license number issued by the State Contractor's Board 32166-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718/2232
Signed Bill Sutton Edmund Miller
By driller performing actual drilling on site or contractor
Date 3/21/03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627