



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48492

1. OWNER JEFF TURK ADDRESS AT WELL LOCATION
 MAILING ADDRESS 3500 Bacon Rind Road 5165 Jackalope Road
Reno, Nevada 89510 Reno, Nevada 89510

2. LOCATION NW 1/4 SE 1/4 Sec. 31 T. 22N N/S R. 21 E Washoe County
 PERMIT NO. 079-180-29 Palomino Valley
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Weathered granite		1	16	15
Rusty weathered granite		16	21	5
Weathered granite		21	63	42
White hard granite		63	139	76
Weathered hard granite		139	222	83
Gray granite		222	261	41
Brown volcanic with weathered granite		261	328	67
Soft weathered rusty granite (NO WATER)		328	360	32
Weathered granite		360	481	121
Fracture weathered granite		481	503	22
Soft zone (NO WATER)		503	510	7
Weathered granite		510	570	60
Soft fractured granite	X	570	617	47
Weathered granite		617	623	6

8. WELL CONSTRUCTION

Depth Drilled 623 Feet Depth Cased 623 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10</u> Inches	<u>0</u> Feet	<u>50</u> Feet
<u>8 5/8</u> Inches	<u>50</u> Feet	<u>623</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>0</u>	<u>623</u>

Perforations:

Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around

From 557 feet to 617 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 623 feet

RECEIVED
 03 AUG 15 AM 11:20
 STATE ENGINEERS OFFICE

Date started August 4, 2003, 19_____
 Date completed August 8, 2003, 19_____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>		

9. WATER LEVEL

Static water level 530 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [Signature]
 Date August 11, 2003