

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49125  
 1219 Golden Eagle Ct.  
 CARONVILLE, NV 89410

1. OWNER RAM Builders Inc  
 MAILING ADDRESS 2541 Henning LN  
CARONVILLE NV 89410  
 ADDRESS AT WELL LOCATION 1219 Golden Eagle Ct.  
CARONVILLE, NV 89410  
 2. LOCATION NW 1/4 SW 1/4 Sec. 01 T. 12 N. R. 20 E Douglas County  
 PERMIT NO. 1220 01 002 044 Sterling RANCH ESTARS  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
soil clay sm, gravel, cobbles		0	4	4
HARD PAN (cemented soil gravel cobbles)		4	11	7
SAND gravel small cobbles		11	65	54
clay		65	83	18
SAND gravel sm cobbles		83	104	21
clay		104	120	16
SAND gravel sm COBBLES	X	120	170	50
clay		170	185	15
SAND gravel sm COBBLES CLAY	X	185	200	15
CLAY		200	210	10
SAND gravel sm COBBLES	X	210	230	20
CLAY		230	240	10

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 240 Feet  
 From \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.98		.188	+2	180

Perforations:  
 Type perforation factory slot  
 Size perforation 3/32 X 3"  
 From 180 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

Date started 6-26-03 19\_\_\_\_  
 Date completed 6-29-03 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25+</u>		<u>2.5</u>

9. WATER LEVEL  
 Static water level 102 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.1 °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sierra Nevada Drilling & Pump LLC  
 Address 3540 Green Acres Dr  
Carson City NV 89705  
 Nevada contractor's license number issued by the State Contractor's Board 18 652078  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902  
 Signed John B. Jensen  
 By driller performing actual drilling on site or contractor  
 Date 7-1-03