WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90798
Permit No.
Basin 105

NOTICE OF INTENT NO. 49013

1. OWNER Jim Megerle
MAILING ADDRESS
ADDRESS AT WELL LOCATION 100 Hwy 395 Gardnerville, Nv.

2. LOCATION SE ¼ NW ¼ Sec. 09 T. 11 N/S R. 21 E. Douglas County
PERMIT NO. (Issued by Water Resources) 1121-09-000-002 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 16 | |
| Volcanic Soft | | 16 | 143 | |
| Hard volcanic | | 143 | 151 | |
| Hard volcanic Fractured Cracks | ✓ | 151 | 200 | |

RECEIVED 03 JUL 14 PM 2:55 STATE ENGINEERS OFFICE

Date started 7-9, 2003
Date completed 7-10, 2003

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| Produced about 50 GPM | | |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 100 Feet |
| 7 7/8 Inches | 100 Feet | 200 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.00 | 3/16 | +1 | 200 |

Perforations:
Type perforation Mill Slot
Size perforation 1/4
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 81 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lynch Drilling Inc (Contractor)
Address PO Box 597 (Contractor)
Silver Springs NV. 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1077
Signed (By driller performing actual drilling on site or contractor)
Date 7-11-03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627