

OFFICE USE ONLY  
 Log No. 90800  
 Permit No. 189  
 Basin. 189

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45811

1. OWNER Robert & Jerilyn Clayton ADDRESS AT WELL LOCATION Approximately  
 MAILING ADDRESS 8365 So. Hauck Street 10 Miles South of Ely  
Las Vegas, Nevada 89139

2. LOCATION SE 1/4 NE 1/4 Sec. 26 T. 14 N. R. 63 E White Pine County  
 PERMIT NO. APN 012-100-12 Ward Mountain  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Alluvial gravels		3	20	17
Orange shale		20	28	8
Grey shale		28	70	42
Clay		70	100	30
Orange shale		100	105	5
Fractured limestone	X	105	110	5
Altered limestone		110	130	20
Limestone		130	170	40
Fractured limestone	X	170	180	10
Limestone		180	210	30
Limestone & calcite	X	210	220	10
Limestone		220	260	40
Shaley limestone		260	270	10
Limestone		270	290	20
Orange shale & limestone		290	300	10
Limestone		300	330	30
Fractured limestone	X	330	340	10
Limestone		340	400	60

8. WELL CONSTRUCTION  
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 400 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	400

Perforations:  
 Type perforation Factory  
 Size perforation 1/8" x 2" 6 Rows  
 From 100 feet to 140 feet  
 From 200 feet to 400 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 Feet  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 400 feet

9. WATER LEVEL  
 Static water level 7 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue Contractor  
Ely, Nevada 89301  
 Nevada contractor's license number issued by the State Contractor's Board 14790  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793  
 Signed Rich Lewis By Harold D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date September 9, 2003

Date started August 18, 2003  
 Date completed September 4, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>350</u>	<u>1-1/2</u>

RECEIVED  
 03 SEP 12 AM 10:56  
 STATE ENGINEERS OFFICE