WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90801
Permit No.
Basin 105

NOTICE OF INTENT NO. 49037

1. OWNER JACK SIEVERS
MAILING ADDRESS 4875 LONGLY LANE
RENO, NV 89502

ADDRESS AT WELL LOCATION JACK DRIVE, KINGSBURY, NV

2. LOCATION NE 1/4 SE 1/4 Sec. 19 T 13N N/S R 19E E DOUGLAS County
PERMIT NO. (Issued by Water Resources) 11-323-16 (Parcel No.) TRACT OF LAND (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [X] Other BORE

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DECOMPOSED GRANITE		0	10	10
GRANITE		10	750	740
	138			
	598			
	670			

Sealed hole with bentonte to 50 feet. Cement from 0-50 feet

RECEIVED 03 SEP 11 AM 11:42 STATE ENGINEERS OFFICE

Borehole only
Did not case -
did not input
test info

Date started 8/16/2003, 19__
Date completed 8/27/2003, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
138'	<.5		.25
598'	<.5		.25
675'	2		.5

8. WELL CONSTRUCTION
Depth Drilled 750 Feet Depth Cased none Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
5.5	Inches	0	Feet	750	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
NA				

Perforations:
Type perforation NA
Size perforation NA
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet
From ___ feet to ___ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From ___ feet to ___ feet

9. WATER LEVEL
Static water level 500 feet below land surface
Artesian flow ___ G.P.M. ___ P.S.I.
Water temperature ___ °F Quality ___

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC (Contractor)
Address P.O.BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1408
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 9/9/2003

USE ADDITIONAL SHEETS IF NECESSARY