COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90806
Permit No.
Basin 105

NOTICE OF INTENT NO. 49694

1. OWNER JEFF KIRBY CONSTRUCTION
MAILING ADDRESS 2972 SAN MATEO DR
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 1900 WISEMAN LN
GARDNERVILLE, NV 89410

2. LOCATION NE ¼ NE ¼ Sec 25 T 12 N R 20 E DOUGLAS County

PERMIT NO. | Issued by Water Resources | 1220-25-102-003 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
COURSE GRAVELS		3	56	53
BOULDERS				
SMALL OBSIDIAN		56	125	69
GRAVELS BOULDERS				
FRACTURED GRANITE		125	152	27
COBBLES & GRAVELS				
FRACTURED GRAVELS	XXX	152	180	28

RECEIVED 03 SEP 10 AM 11:03 STATE ENGINEERS OFFICE

Date started 8/25, 20 03
Date completed 8/27, 20 03

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	35	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 180' Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:
Type perforation FACTRORY MILL SLOT
Size perforation 3 X 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 180 feet

9. WATER LEVEL

Static water level 80 feet below land surface
Artesian flow G.P.M 20 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed [signature] By driller performing actual drilling on site or contractor
Date 8/15/03