

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 90807  
 Permit No. \_\_\_\_\_  
 Basin 105  
 NOTICE OF INTENT NO. 49696

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **KIM POSNIEN CONSTRUCTION** ADDRESS AT WELL LOCATION **261 FREDRICKS BURG RD**  
 MAILING ADDRESS **440 FOOTHILLS RD** **GARDNERVILLE, NV 89410**

2. LOCATION NW 1/4 NW 1/4 Sec 36 T 12 N R 19 E **DOUGLAS County**  
 PERMIT NO. SE SE **1219-36-002-013**

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG SANDS AND BOULDERS		0	23	23
LARGE GRANITE BOULDERS		23	45	22
COURSE DG SANDS AND CLAY SEAMS		45	98	53
FRACTURED SLATE AND OBSIDIAN SANDS		98	125	27
FRACTURED DG SANDS	XXX	125	180	55

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 0 Feet 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:  
 Type perforation MILL SLOT  
 Size perforation 3 X 3/32  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 180 feet

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **CAPITAL CITY WELL DRILLING**  
 (CONTRACTOR)

Address **20 KIT KAT DRIVE**  
 (CONTRACTOR)  
**CARSON CITY, NV 89706**  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157  
 Signed Bill Crane  
 By driller performing actual drilling on site or contractor  
 Date 8/30/03

Date started 8/28, 20 03  
 Date completed 8/30, 20 03

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>25</u>	<u>35</u>	<u>3 HRS</u>	

RECEIVED  
 03 SEP 10 AM 11:03  
 STATE ENGINEERS OFFICE