WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90815
Permit No.
Basin 105

NOTICE OF INTENT NO. 48675

1. OWNER Madeline + Steven Hollstrom
MAILING ADDRESS 362 Lincoln Ave
Livermore, Ca 94550
ADDRESS AT WELL LOCATION 2565 Leviathan Mine Rd
Gardnerville NV

2. LOCATION E½ NW¼ SW¼ Sec. 22 T. 11 N/S R 21 E Douglas County
PERMIT NO. (Issued by Water Resources) 1121-22-000-017 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND+BOULDERS		0	40	40
RED+GREY ROCK		40	80	40
BLACK+GREY ROCK		80	140	60
BROKEN BLACK+GREY ROCK		140	150	10
BLACK, GREY+WHITE ROCK		150	170	20
BROKEN BLACK, GREY WHITE ROCK		170	175	5
BLACK+WHITE ROCK		175	210	35
BLACK+GREEN ROCK		210	218	8
BLACK, GREY ROCK		218	260	48
BLACK, GREY, GREEN, WHITE BROKEN ROCK		260	300	40

RECEIVED 03 AUG 18 PM 1:11 STATE ENGINEERS OFFICE

Date started 5-6-03, 20
Date completed 5-9-03, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-20		2

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	0	300

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:
Type perforation FACTORY
Size perforation
From 260 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 300 feet to 50 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow cold G.P.M. P.S.I.
Water temperature F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA PUMP & DRILLING (Contractor)
Address P.O. BOX 2227 (Contractor)
DAYTON, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 46357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187
Signed Thomas Evans (By driller performing actual drilling on site or contractor)
Date

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627