

OFFICE USE ONLY  
 Log No. 90820  
 Permit No. 5045-1  
 Basin. 061  
 NOTICE OF INTENT NO. 43666

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Lander County ADDRESS AT WELL LOCATION 1080 Airport Road  
 MAILING ADDRESS 1080 Airport Road

2. LOCATION NW 1/4 NE 1/4 Sec. 35 T. 33 N/S R. 45 E Lander County  
 PERMIT NO. 50451 Parcel No. 11-240-03 Subdivision Name N/A

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

| Material   | Water Strata | From | To  | Thick-ness |
|------------|--------------|------|-----|------------|
| Clay       |              | 0    | 12  |            |
| SAND       |              | 12   | 15  |            |
| Clay Brown |              | 15   | 55  |            |
| Clay BLUE  |              | 55   | 80  |            |
| Black SAND |              | 130  | 145 |            |
| Blue Clay  |              | 145  | 150 |            |
| SAND       |              | 150  | 200 |            |
| Clay       |              | 200  | 205 |            |
| SAND       |              | 205  | 215 |            |
| Clay       |              | 215  | 220 |            |
| SAND       |              | 220  | 225 |            |
| Clay       |              | 225  | 232 |            |
| SAND       |              | 235  | 239 |            |
| Clay       |              | 239  | 242 |            |

8. WELL CONSTRUCTION  
 Depth Drilled 242 Feet Depth Cased 241 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
30 Inches 0 Feet 52' Feet  
24 Inches 52 Feet 242 Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 26"                |                     | .250                    | -10         | 52        |
| 16"                |                     | .250                    | -8*         | 241       |

Perforations:  
 Type perforation Double Row 0.90 mill slot  
 Size perforation  
 From 160 feet to 240' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 52'  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From -8 feet to 241 feet

\* A 16" industrial P. T. less was welded at 6' and is 2' above ground level. A 3" pipe was welded to the top of the plate that seals between the 26" + 16" plate to add gravel. A 1" pipe was welded to the 16" below P. T. less around the well.

Date started 2003  
 Date completed 2003

7. WELL TEST DATA

| TEST METHOD:   | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|--------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift |        |                               |              |
| Airlift  | 300    | ?                             | 32           |
| Constant   | 420    | 53                            | 24           |

9. WATER LEVEL  
 Static water level 15' feet below land surface  
 Artesian flow ND G.P.M. NA P.S.I.  
 Water temperature Cool °F Quality Test in progress

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED ANDERSON Drilling Contractor  
 Address 10760 Grass Valley Road Contractor  
Winn, NV 89445  
 Nevada contractor's license number issued by the State Contractor's Board 021467  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5-10-2003