

OFFICE USE ONLY
 Log No. 90821
 Permit No. 21412
 Basin. 069

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44236

1. OWNER NEVADA FIRST CORPORATION ADDRESS AT WELL LOCATION GRAYSON HOME RANCH
 MAILING ADDRESS PO Box 490
WINNEMUCCA, NV 89446

2. LOCATION SE 1/4 SE 1/4 Sec. 18 T 40 N S R 40 E HUMBOLDT County
 PERMIT NO. 21412 7030
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other REVERSE

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	13	13
SAND + SM GRAVEL		13	20	
TAN CLAY		20	65	
SAND + GRAVEL		65	76	
BLENT CLAY		76	84	
SAND + GRAVEL		84	161	
CLAY w/SAND GRAVEL		161	163	
SAND + GRAVEL		163	288	
CLAY w/SAND GRAVEL		288	300	
SAND + GRAVEL		300	338	

8. WELL CONSTRUCTION
 Depth Drilled 338 Feet Depth Cased 338 Feet

HOLE DIAMETER (BIT SIZE)
 From 28 Inches To 0 Feet 338 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16"</u>		<u>.375</u>	<u>+2</u>	<u>138</u>

Perforations:
 Type perforation 16" JOHNSON WIRE WRAP SCREEN
 Size perforation SLOT SIZE .040
 From 138 feet to 338 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50'
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 50' feet to 338 feet

9. WATER LEVEL
 Static water level 17 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name RIVERSIDE, INC Contractor
 Address PO Box 720 Contractor
PARMA, ID 83660

Nevada contractor's license number issued by the State Contractor's Board 004881
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1919

Signed [Signature]
 By driller performing actual drilling on site or Contractor
 Date 6-27-03

Date started MAY 27, 2003
 Date completed JUNE 9, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>NO WELL TEST DONE</u>		

RECEIVED
 03 JUL -3 AM 11:00
 STATE ENGINEERS OFFICE