

OFFICE USE ONLY
 Log No. 90827
 Permit No. 084
 Basin. 48418

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48418

1. Consultant: HALEY & ALDRICH, INC. Client: The Boeing Company
 1. OWNER: HALEY & ALDRICH, INC. ADDRESS AT WELL LOCATION: The Boeing Company
 MAILING ADDRESS: 326 S. Wilmont Road, Suite A200 5600 Whiskey Springs Road
Tucson, AZ 85711-4029 Reno, Nevada 90510
 2. LOCATION: SE 1/4 NE 1/4 Sec. 28 T. 22N N/S R. 21 E Washoe County
 PERMIT NO. Well E-3A 076-242-05 Palomino Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL ABANDONMENT/PLUGGING				
Measure Static Water Level @134.8 feet				
Total Depth @162 feet				
Set tremie pipe to bottom of casing				
Pump neat cement from bottom to surface, 20 sacks				
Pull tremie pipe				
Remove surface completion and concrete pad, cut casing below grade. Cement full at top.				
Backfill with native materials				
Equipment used:				
Ingersoll-Rand T4W Drill Master, Ford LT9000				
Service/Water Truck, Ford F-450 Support Truck				
Tremie Pipe				
Generator				
Grout Pump & Mixer (high pressure)				
Materials Used:				
20 sack Portland Cement Type II				
Location:				
31 feet to North Parcel Boundary				
229 feet to East Parcel Boundary				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From	To
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet
_____ Inches	_____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____
 Size perforation _____

From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 5-20-03
 Date completed 5-21-03

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [Signature]
 Date May 28, 2003

7. WELL TEST DATA LAS VEGAS OFFICE

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)