

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48419

1. Consultant: HALEY & ALDRICH, INC. Client: _____
 OWNER: _____ ADDRESS AT WELL LOCATION The Boeing Company
 MAILING ADDRESS 326 S. Wilmont Road, Suite A200 5600 Whiskey Springs Road
Tucson, AZ 85711-4029 Reno, Nevada 89510
 2. LOCATION SE 1/4 NE 1/4 Sec. 28 T. 22N N/S R. 21 E Washoe County
 PERMIT NO. Well E-4A 076-242-05 Palomino Valley
 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL ABANDONMENT/PLUGGING				
Measure Static Water Level @ <u>139.9</u> feet				
Total Depth of Well @ <u>166</u> feet				
Set tremie pipe to bottom of casing				
Pump neat cement from bottom to surface, <u>21</u> sacks				
Pull tremie				
Remove surface completion and concrete pad, cut casing below grade. Top off with <u>1</u> sack cement, back fill with native materials				
Equipment used:				
<u>Ingersoll-Rand T4W Drill Master, Ford LT9000</u>				
<u>Service /Water Truck, Ford F-450 Support Truck</u>				
<u>Tremie Pipe</u>				
<u>Generator</u>				
<u>Grout Pump & Mixer (high pressure)</u>				
Materials used:				
<u>22 sacks Portland Cement Type IP:</u>				
Location:				
<u>292 feet to North Parcel Boundry</u>				
<u>614 feet to East Parcel Boundry</u>				

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>				

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date May 28, 2003

7. WELL TEST DATA
 TEST METHOD: Bailer Pump Air Lift
 G.P.M. _____ Drawdown (Feet Below Station) 25 Time (Hours) _____
RECEIVED
SEP 25 2003
LAS VEGAS OFFICE