WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 90847
Permit No.
Basin 104

NOTICE OF INTENT NO. 49323

1. OWNER Brian & Joanne Brentlinger
MAILING ADDRESS 1790 Valley View Dr.
Carson City, NV 89701

ADDRESS AT WELL LOCATION 1790 Valley View Dr.

2. LOCATION NW 1/4 SW 1/4 Sec. 28 T 15N N/S R 20E E Carson County
PERMIT NO. (Issued by Water Resources) Parcel No. 10-322-17 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6 5/8" well by perforating from about 140' to 90' where we hit a seal. We were able to perforate again from about 25' to surface. We used a Mills Knife and perforated at 4 around and at one foot intervals. There was no well log available. Estimated depth was 160'. We then pumped approximately 2 cu. yards of neat cement from bottom to top and cut the top 2' off of the casing.				

RECEIVED
03 OCT -9 AM 11:15
STATE ENGINEERS OFFICE

Date started 9/10/2003 , 19__
Date completed 9/10/2003 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	160

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 140 feet to 90 feet
From 25 feet to 0 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 160
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 123 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 9/12/03

USE ADDITIONAL SHEETS IF NECESSARY