

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 90859
 Permit No. _____
 Basin 092A



NOTICE OF INTENT NO. -51515

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Truckee Meadows Water Authority (RSMW-S) ADDRESS AT WELL LOCATION 1050 El Rancho Drive, Reno, NV.
 MAILING ADDRESS 155 Corporate Boulevard Reno, NV 89510

2. LOCATION NE 1/4 SE 1/4 Sec. 6 T 19N N/S R 20 E Washoe County
 PERMIT NO. R-16 Issued by Water Resources Parcel No. 031-012-01 Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel, boulders		0	30	30
Gravel		30	45	15
Brown clay		45	85	40
Sand with clay		85	140	55
Sand, gravel		140	156	16
Clay with gravel		156	162	6
Brown clay		162	180	18
Coarse sand		180	185	5
Gray clay		185	191	6
Brown clay		191	205	14

Construction Detail:

Cement	0	102
Hole plug	102	118
Gravel pack	118	205

RECEIVED
 03 OCT 14 PM 3:11
 STATE ENGINEERS OFFICE

Date started 9/24/2003, 19
 Date completed 9/25/2003, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift G.P.M. <u>20</u>	<u>Not Meas.</u>	<u>8</u>

8. WELL CONSTRUCTION

Depth Drilled 205 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>12.25</u>	<u>0</u>	<u>20</u>	<u>20</u>	<u>20</u>
<u>6.50</u>	<u>20</u>	<u>205</u>	<u>205</u>	<u>205</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>7.625</u>	<u>26.45</u>	<u>0.340</u>	<u>+2</u>	<u>20</u>
<u>2.500</u>		<u>Sch. 80</u>	<u>+1.7</u>	<u>200</u>

Perforations:
 Type perforation Slot
 Size perforation 0.050"

From <u>130</u> feet to <u>200</u> feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 102'
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 118 feet to 205 feet

9. WATER LEVEL

Static water level 66.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
 Signed Adalberto Jacobo
 By driller performing actual drilling on site or contractor
 Date 10/3/03

B.S.T.C